

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CPR/W/26-27/R/284

Dated: 20-08-2026

It is certified that an inspection team headed by ALOK KUMAR

(Name of Officers with designation) from Asst. Chemist, Dutt water testing Lab, Chapra.

(Name of Department/ Office) inspected the Saraswati Shishu vidya mandir, Chapra-841301

(Name & Address of the school) on 14-08-26 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 20-08-2026 to 19-08-2027

Signature with Seal:

Name

Designation :

Assistant Engineer of the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Public Health Eng. Dept.
Name & Address of the Office Department :

To

Saraswati Shishu vidya

Mandir, Darshan Nagar
Chapra- 841301

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



District Level Laboratory(PHED) Chapra, Saran



DOC NO: CPR / SAMP / 05/00

TEST REPORT

Name & Address:- Mr. Prakash Kumar Saraswati Shishu Vidya Mandir, Chapra, Darshan Nagar Chapra (Saran) Bihar -841301	Report No. : CPR/W/26-27/R/284 Date : 20.08.26 Sample Description : Drinking Water Sample Mark/ Location : R/W Sample Collected on : 14.08.26 Sampling Plan & Method : IS 17614(Part 1): 2021 Date of Performance (s) : 20.08.26
--	---

Analysis Result

Sl. No.	Test Parameter	Unit	Test Method	IS 10500:2012Amd. 1 & 2		Result
				Acceptable Limit	Permissible Limit	
1	Colour	HU	IS 3025 (Part 4) : 2021	5	15	1
2	Odour		IS 3025 (Part 5) : 2018	Agreeable	NR	Agreeable
3	Taste		IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 ⁰ C		IS 3025(Part 11) : 2022	6.5	8.5	7.3
5	Turbidity	NTU	IS 3025(Part 10) : 2023	1	5	0.91
6	TDS	mg/l	IS 3025(Part 16) : 2023	500	2000	201
7	Total Hardness (as CaCO ₃)	mg/l	IS 3025(Part 21) : 2009	200	600	154
8	Calcium (as Ca)	mg/l	IS 3025(Part 40) : 1991	70	200	34
9	Magnesium (as Mg)	mg/l	IS 3025(Part 46) : 1994	30	100	14
10	Chloride (as Cl)	mg/l	IS 3025(Part 32) : 1988	250	1000	18
11	Total Alkalinity (as CaCO ₃)	mg/l	IS 3025(Part 23) : 1986	200	600	158
12	Arsenic (as As)	mg/l	APHA 24 th Edition -3500 Method B (Silver Diethyldithiocarbamate Method): 2023	0.01	NR	0.0
13	Iron (as Fe)	mg/l	APHA 24 th Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1	NR	0.03

Remark: *Analysed sample of water within permissible limit, Hence sample is suitable for drinking.*

Memo No: CPR/W/26-27/284 /20/08/2026

A. Kumar
PHED Laboratory, Chapra
Reviewed & Signature 20/08/26

Disclaimer:-

- The report shall not be reproduced except in full, without approval of the laboratory
- The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.